

Tender Clarification 3

Project: Accrington Cemetery & Service Yard

Location: Accrington Cemetery (Service Yard), Burnley Road, Accrington BB5 6HA

Client: Hyndburn Borough Council

Issued by: JPT

Date: 06st April 2022

Ref: **20065 – TC3**

Revision: TC3

A) Omit wording of item 14.3.

B) Add the following wording for item 14.3:

125mm thick PAV2 concrete hard standing to yard area (approx 460m²) on min 200mm compacted MOT Type 1 hardcore sub-base. Allow for movement joints at max 6m centres filled with flexible exterior grade joint sealant.

C) Please find enclosed the following additional tender document:-

New drawing Ref 20065-38 – Proposed Site Levels